BWoF Ltd
Building Compliance Made Easy

Phone: 0204 296 369 (020 4 BWoF NZ)
e-mail: info@bwof.nz
Website: www.bwof.nz
15 Edwin Ebbett Place Wigram, Christchurch

Owners Inspection Record Sheet SS 4 Emergency Lighting System

Monthly check must ensure that:

a) Emergency lighting system operates correctly
b) Operate emergency lighting system for 15 minutes
c) Verify all emergency lights operate correctly
d) Replace bulbs with the correct bulb as necessary
e) Check once repaired
f) Check battery charger and battery levels
g) Any maintenance to be carried out immediately and recorded below
h) Return to standby state with charger on

Months	Inspected by	Date	Comments

Note: